



ERICO France Sarl
Rue Charles Dallière BP 31
42161 Andrézieux-Bouthéon
FRANCE

Client no.
610805

Your reference
Frederic Bizet


Our reference
Markus Jäger

Date
06.06.2025

Authorization

Number:
valid until:

25.0545
09.06.2028



Marking:



Based on the documents contained in file **22-BS-0198**, the Federal Inspectorate for Heavy Current Installations grants the firm named above the right to put the equipment listed below on the market marked with the Swiss safety mark in accordance with the NEV.

Equipment:

Flexbus System

Tradename:

nVent ERIFLEX

Type designation

Nominal values

Type designation	Nominal values				
FLEXCOND220	1000 VAC	1500 VDC	400 kVA	560 A	50/60 Hz
FLEXCOND360	1000 VAC	1500 VDC	500 kVA	704 A	50/60 Hz
FLEXCOND545	1000 VAC	1500 VDC	630 kVA	900 A	50/60 Hz
FLEXCOND640	1000 VAC	1500 VDC	800 kVA	1120 A	50/60 Hz
FLEXCOND960	1000 VAC	1500 VDC	1000 kVA	1400 A	50/60 Hz
FLEXCOND1280	1000 VAC	1500 VDC	1250 kVA	1760 A	50/60 Hz
FLEXCOND1810	1000 VAC	1500 VDC	1600 kVA	2253 A	50/60 Hz





Authorization Number: **25.0545**

Type designation Nominal values

Protection class:

Protection degree: IP55

Basis: Test Report / F-Lab Volta / 202104106_001 / 20.07.2021
Test Report / F-Lab Volta / SPEC21AA1027_V2 / 21.01.2022

Remark:

Test standards: IEC 61439-1(ed.3):2020
IEC 61914(ed.3):2021
IEC 60364-5-52(ed.3):2009
IEC 60364-4-42(ed.3):2010

Federal Inspectorate for Heavy Current Installations ESTI

Severo Nicoli
Head of Market Surveillance/Safety Mark

